



CERTIFICATE

ALLEGATO - ANNEX

Numero commessa
Order number C3/0015/25

Numero di Certificato
Certificate number 0068-GAR-00162

Indice di revisione
Revision index 00

Norme di prova
Test standards EN 88-1:2022+A1:2023

Descrizione dei modelli riferibili al tipo certificato Description of the models related to the certified type

Regolatore di pressione gas con corpo e coperchio in alluminio, con e senza elemento filtrante sostituibile, con le seguenti caratteristiche:

Pressure regulator for gas with aluminium body and cover, with and without replaceable filtering element, having the following characteristics:

	TIPO TYPE	DIMENSIONI DIMENSIONS	DESCRIZIONE DESCRIPTION	P MAX
CAPOSTIPITI PROGENTS	RG015	1/2" (DN15)	Gas Governor	500mBar
	RG020	3/4" (DN20)	Gas Governor	500mBar
	RG025	1" (DN25)	Gas Governor	500mBar
	RG032	1"1/4 (DN32)	Gas Governor	500mBar
	RG040	1"1/2 (DN40)	Gas Governor	500mBar
	RG050	2" (DN50)	Gas Governor	500mBar
	RGD65	DN65	Gas Governor	500mBar
	RGD80	DN80	Gas Governor	500mBar
	RGD100	DN100	Gas Governor	500mBar
	VERSIONI CON FILTRO VERSIONS WITH FILTER			
	RG015-FT	1/2" (DN15)	Gas Governor with Filter	500mBar
	RG020-FT	3/4" (DN20)	Gas Governor with Filter	500mBar
	RG025-FT	1" (DN25)	Gas Governor with Filter	500mBar
	RG032-FT	1"1/4 (DN32)	Gas Governor with Filter	500mBar
	RG040-FT	1"1/2 (DN40)	Gas Governor with Filter	500mBar
	RG050-FT	2" (DN50)	Gas Governor with Filter	500mBar
	RGD65-FT	DN65	Gas Governor with Filter	500mBar
	RGD80-FT	DN80	Gas Governor with Filter	500mBar
	RGD100-FT	DN100	Gas Governor with Filter	500mBar



00162



Per. Ind. Samuele Mantella

MTIC INTERCERT Certification Body



C E R T I F I C A T E

ALLEGATO - ANNEX

	TIPO TYPE	DIMENSIONI DIMENSIONS	DESCRIZIONE DESCRIPTION	P MAX
VARIANTI VARIANTS	VERSIONI CON TEST POINT TPIO VERSIONS WITH TPIO TEST POINT			
	RG015-TPIO	1/2" (DN15)	Gas Governor with Test Point Input/output	500mBar
	RG020-TPIO	3/4" (DN20)	Gas Governor with Test Point Input/output	500mBar
	RG025-TPIO	1" (DN25)	Gas Governor with Test Point Input/output	500mBar
	RG032-TPIO	1"1/4 (DN32)	Gas Governor with Test Point Input/output	500mBar
	RG040-TPIO	1"1/2 (DN40)	Gas Governor with Test Point Input/output	500mBar
	RG050-TPIO	2" (DN50)	Gas Governor with Test Point Input/output	500mBar
	RGD65-TPIO	DN65	Gas Governor with Test Point Input/output	500mBar
	RGD80-TPIO	DN80	Gas Governor with Test Point Input/output	500mBar
	RGD100-TPIO	DN100	Gas Governor with Test Point Input/output	500mBar
	VERSIONI CON FILTRO E TEST POINT TPIO VERSIONS WITH FILTER AND TPIO TEST POINT			
	RG015-FT-TPIO	1/2" (DN15)	Gas Governor with Test Point Input/output & Filter	500mBar
	RG020-FT-TPIO	3/4" (DN20)	Gas Governor with Test Point Input/output & Filter	500mBar
	RG025-FT-TPIO	1" (DN25)	Gas Governor with Test Point Input/output & Filter	500mBar
	RG032-FT-TPIO	1"1/4 (DN32)	Gas Governor with Test Point Input/output & Filter	500mBar
	RG040-FT-TPIO	1"1/2 (DN40)	Gas Governor with Test Point Input/output & Filter	500mBar
	RG050-FT-TPIO	2" (DN50)	Gas Governor with Test Point Input/output & Filter	500mBar
	RGD65-FT-TPIO	DN65	Gas Governor with Test Point Input/output & Filter	500mBar
	RGD80-FT-TPIO	DN80	Gas Governor with Test Point Input/output & Filter	500mBar
	RGD100-FT-TPIO	DN100	Gas Governor with Test Point Input/output & Filter	500mBar
	VERSIONI CON ADATTATORE AD ATTACCO FLANGIATO VERSIONS WITH FLANGE ADAPTER			
	RGD25	1" (DN25)	Gas Governor with Test Point Input/output	500mBar
	RGD32	1"1/4 (DN32)	Gas Governor with Test Point Input/output	500mBar
	RGD40	1"1/2 (DN40)	Gas Governor with Test Point Input/output	500mBar
	RGD50	2" (DN50)	Gas Governor with Test Point Input/output	500mBar
	LE VERSIONI FLANGIATE POSSONO ESSER ANCHE -FT, -TPIO O ENTRAMBE THE FLANGED VERSIONS CAN ALSO BE -FT, -TPIO OR BOTH			

Gruppo / Group	2
Classe / Class	A
Tipi di gas utilizzati / Types of used gas	I, II e III famiglia / Family
Temperature di utilizzo / Operating temperature range	Da / From -20°C a / to +60°C



00162



Per. Ind. Samuele Mantella

MTIC INTERCERT Certification Body